


4V3AH






Outer dimensions(mm)




Specifications

Nominal Voltage		4V		Rated Capacity (20 hour rate)		3.0AH
	Length	66mm	2.60 inches	Weight	Approx:	335g
Dimensions ±1mm	Width	33mm	1.30 inches	Standard Terminal		F1
	Height	75mm	2.95 inches			
	Total Height	81 mm	3.19 inches	Optio	onal	
	(With Terminals)			Term	ninal	F2




F2 Terminal (Brass Coated with Silver)



Specifications

Nominal Voltage		4V		Rated Capacity (20 hour rate)		3.0AH
	Length	66mm	2.60 inches	Weight	Approx:	335g
Dimensions ±1mm	Width	33mm	1.30 inches	Standard		F1
	Height	75mm	2.95 inches	Terminal		
	Total Height	81 mm	3.19 inches	Optional		
	(With Terminals)			Term	ninal	F2


·Discharge Characteristics (25°C/77°F)



Electrical Specifications

Capacity 77°F(25℃)	20 hour rate (150mA)	3.0AH	Internal Resistance			
	10 hour rate (270mA)	2.7AH			30 mΩ	
	5 hour rate (510mA)	2.6AH	Full charged battery 77°F (25℃)			
	1 hour rate(1800mA)	1.8AH				
Capacity Affected by Temperature (20 hour rate)	104°F (40℃)	102%		Capacity after 1 month storage 90%		
	77°F (25℃)	100%	Self- discharge	Capacity after 3 month storage 75%		
	32°F (0℃)	80%	77°F(25℃)	Capacity after 6 month storage 65%		
	5°F (−15°C)	50%		Capacity after 12 month storage 55%		
Charge Constant Voltage	Cycle use:Initial Charging Current less than 0.90A;Voltage 4.80~5.00V 77°F(25°C) Standby use:Voltage 4.50~4.60V 77°F(25°C)					

· Discharge Characteristics(0°C/32°F-40°C/104°F)



Maintenance and Attention Matters:

- 1. Battery is not allowed close to Tepid source or basked under the sun for a long time.
 - 2. No charge in the obturate container
- **3.** No short circuit. Battery should be stored full of electronic when not in need, and the battery should be charged every three months in order to avoid the irreversible sulphation. When battery case bursts or electrolyte leaks, battery should be changed lest the acid corrosion.
 - **4.** No battery in environment with the acid gas.
- 5. When battery is used as the backup battery, be careful and check it at regular time to avoid the damage battery. Especially the battery beyond one year should be checked in time, and change the less capacity and scrapped battery. (some batteries maybe have voltage but no current; some batteries maybe have current but no voltage; some maybe have both but less capacity: all these conditions cannot meet the work, reach the power—on time. Do not for the small battery, cause the huge losses)
- **6.** Forbidden battery in the fire, otherwise it will cause an explosion.

- 7. When battery cracks or electrolyte leaks, please use cotton cloth clear it. When skin contacts to the liquid, please wash with fresh water immediately. See doctor if serious.
- 8. No wash on the surface of the battery with the organic solution.